



New Jersey Department of Health  
Environmental and Chemical Laboratory Services  
PO Box 361, Trenton, NJ 08625-0361  
NJDEP Lab ID#: 11036  
EPA Lab ID#: NJ01351

Client Address:  
La Casa de Don Pedro Center III  
202-216 First Street  
Newark NJ, 7107

Report Date: 02/27/2026 10:32  
Project: NIDCF Childcare Drinking Water

Client Sample ID: **Kitchen Sink**  
Sample Location:  
Field ID No: Kitchen Sink  
Sample Type: First Draw

Lab Number: 25G1806-01  
Sampled: 1/21/2026 6:58:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 19.5   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:09 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:09 | EPA 200.8 |

NJDOH PHEL

Dave Riker, Organic Testing Laboratory Supervisor

Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: Kitchen Sink Hose  
Sample Location:  
Field ID No: Kitchen Sink Hose  
Sample Type: First Draw


Lab Number: 25G1806-02  
Sampled: 1/8/2026 7:02:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 14.2   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:53 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:53 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Kitchen Dishwasher Hose**  
Sample Location:  
Field ID No: Kitchen Dishwasher Hose  
Sample Type: First Draw

Lab Number: 25G1806-03  
Sampled: 1/8/2026 7:05:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 12.3   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 14:37 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 14:37 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: Kitchen Handwash Sink  
Sample Location:  
Field ID No: Kitchen Handwash Sink  
Sample Type: First Draw

Lab Number: 25G1806-04  
Sampled: 1/8/2026 7:08:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 11.2   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:15 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:15 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Kitchen Restroom Sink**  
Sample Location:  
Field ID No: Kitchen Restroom Sink  
Sample Type: First Draw


Lab Number: 25G1806-05  
Sampled: 1/8/2026 7:10:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 12.8   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:16 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:16 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Office Water Cooler**  
Sample Location:  
Field ID No: Office Water Cooler  
Sample Type: First Draw

Lab Number: 25G1806-06  
Sampled: 1/8/2026 7:12:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 37.3   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:18 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:18 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Room F-1 Sink Middle**  
 Sample Location:  
 Field ID No: Room F-1 Sink Middle  
 Sample Type: First Draw

Lab Number: 25G1806-07  
 Sampled: 1/8/2026 7:15:00AM  
 Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 37.9   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:19 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:19 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: Room F-1 Sink Regular  
Sample Location:  
Field ID No: Room F-1 Sink Regular  
Sample Type: First Draw

Lab Number: 25G1806-08  
Sampled: 1/8/2026 7:17:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 12.3   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:21 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:21 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Room F-II Sink Regular**  
Sample Location:  
Field ID No: Room F-II Sink Regular  
Sample Type: First Draw

Lab Number: 25G1806-09  
Sampled: 1/8/2026 7:23:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 12.3   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:22 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:22 | EPA 200.8 |

NJDOH PHEL

  
Dave Riker, Organic Testing Laboratory Supervisor

  
Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Room F-III Sink Middle**  
Sample Location:  
Field ID No: Room F-III Sink Middle  
Sample Type: First Draw


Lab Number: 25G1806-10  
Sampled: 1/21/2026 7:03:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 55.1   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:27 | EPA 200.8 |
| Lead                                    | 0.268  | JR        | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:27 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Room F-III Sink Regular**  
Sample Location:  
Field ID No: Room F-III Sink Regular  
Sample Type: First Draw


Lab Number: 25G1806-11  
Sampled: 1/8/2026 7:30:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 12.8   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:29 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:29 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Hallway Restroom**  
Sample Location:  
Field ID No: Hallway Restroom  
Sample Type: First Draw

Lab Number: 25G1806-12  
Sampled: 1/8/2026 7:35:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 11.6   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:30 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:30 | EPA 200.8 |

  
Dave Riker, Organic Testing Laboratory Supervisor

  
Doug Haltmeier, Inorganic Testing Laboratory Supervisor


Client Sample ID: **Staff Lounge Cooler**  
Sample Location:  
Field ID No: Staff Lounge Cooler  
Sample Type: First Draw

Lab Number: 25G1806-13  
Sampled: 1/8/2026 7:38:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 14.3   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:32 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:32 | EPA 200.8 |

NJDOH PHEL

  
\_\_\_\_\_  
Dave Riker, Organic Testing Laboratory Supervisor

  
\_\_\_\_\_  
Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Room F-IV Sink**  
Sample Location:  
Field ID No: Room F-IV Sink  
Sample Type: First Draw

Lab Number: 25G1806-14  
Sampled: 1/21/2026 6:59:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 334    |           | 0.136                     | 0.500              | ug/L  | 02/06/2026 | 02/18/2026 14:17 | EPA 200.8 |
| Lead                                    | 3.69   |           | 0.112                     | 1.00               | ug/L  | 02/06/2026 | 02/18/2026 14:17 | EPA 200.8 |

NJDOH PHEL

  
\_\_\_\_\_  
Dave Riker, Organic Testing Laboratory Supervisor

  
\_\_\_\_\_  
Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Room F-IV & F-V Restroom Sin**  
Sample Location:  
Field ID No: Room F-IV & F-V Restroom Sink (close  
Sample Type: First Draw


Lab Number: 25G1806-15  
Sampled: 1/21/2026 7:05:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 41.8   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:33 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:33 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Room F-V Sink**  
Sample Location:  
Field ID No: Room F-V Sink  
Sample Type: First Draw


Lab Number: 25G1806-16  
Sampled: 1/8/2026 7:50:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 14.2   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:35 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:35 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Room F-IV & F-V Restroom Sin**  
Sample Location:  
Field ID No: Room F-IV & F-V Restroom Sink (close  
Sample Type: First Draw

Lab Number: 25G1806-17  
Sampled: 1/8/2026 7:53:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 12.8   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:36 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:36 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Room F-IV & F-V Restroom Sin**  
Sample Location:  
Field ID No: Room F-IV & F-V Restroom Sink  
Sample Type: First Draw

Lab Number: 25G1806-18  
Sampled: 1/8/2026 7:45:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 11.6   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:38 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:38 | EPA 200.8 |

NJDOH PHEL

  
\_\_\_\_\_  
Dave Riker, Organic Testing Laboratory Supervisor

  
\_\_\_\_\_  
Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Room F-VII Left Sink**  
Sample Location:  
Field ID No: Room F-VII Left Sink  
Sample Type: First Draw


Lab Number: 25G1806-19  
Sampled: 1/8/2026 7:56:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 11.7   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:39 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:39 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

New Jersey Department of Health

Client Sample ID: **Room F-VIII Sink Middle**

Sample Location:

Field ID No: Room F-VIII Sink Middle

Sample Type: First Draw

Lab Number: 25G1806-22

Sampled: 1/8/2026 8:20:00AM

Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 37.4   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:47 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:47 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Room F-VIII Sink Regular**

Sample Location:

Field ID No: Room F-VIII Sink Regular

Sample Type: First Draw

Lab Number: 25G1806-23

Sampled: 1/8/2026 8:18:00AM


Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 38.3   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:48 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:48 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor


Client Sample ID: **Room F-VIII Restroom Sink**  
 Sample Location:  
 Field ID No: Room F-VIII Restroom Sink  
 Sample Type: First Draw

Lab Number: 25G1806-24  
 Sampled: 1/8/2026 8:15:00AM  
 Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 36.9   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 13:59 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 13:59 | EPA 200.8 |

NJDOH PHEL

  
 \_\_\_\_\_  
 Dave Riker, Organic Testing Laboratory Supervisor

  
 \_\_\_\_\_  
 Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **D1 Blank**  
Sample Location:  
Field ID No: D1 Blank  
Sample Type: First Draw

Lab Number: 25G1806-25  
Sampled: 1/8/2026 8:15:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 12.2   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 14:01 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 14:01 | EPA 200.8 |

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Hallway Restroom**  
Sample Location:  
Field ID No: Hallway Restroom  
Sample Type: First Draw

Lab Number: 25G1806-26  
Sampled: 1/8/2026 8:13:00AM  
Received: 1/14/2026 11:00:33AM

| Analyte                                 | Result | Qualifier | Method<br>Detection Limit | Reporting<br>Limit | Units | Prepared   | Analyzed         | Method    |
|-----------------------------------------|--------|-----------|---------------------------|--------------------|-------|------------|------------------|-----------|
| <b>Metals by EPA 200 Series Methods</b> |        |           |                           |                    |       |            |                  |           |
| Copper                                  | 11.9   |           | 0.113                     | 0.500              | ug/L  | 01/30/2026 | 02/03/2026 14:02 | EPA 200.8 |
| Lead                                    | K      |           | 0.100                     | 1.00               | ug/L  | 01/30/2026 | 02/03/2026 14:02 | EPA 200.8 |

Notes and definitions:


- J Approximate Value
- JR Approximate value. Result is below the reporting level but greater than the method detection limit.

Case Narrative Section:

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor